



Danfoss A/S
Industrial & Appliance Controls

Head Office
DK 6430 Nordborg, Denmark
Reg. No: 31 744
Giro: 9 03 54 51

Telefax
International + 45 74 49 09 49

Telex: 50 599 danfss dk

Telephone
International + 45 74 88 22 22

DECLARATION

Danfoss A/S
Industrial & Appliance Controls

declare under our sole responsibility that the products:



AKS Pressure Transmitters

AKS 32, AKS 32R, AKS 33, AKS 3000, AKS 3050; AKS 1008

Code No's 060Gxxxx

are classified for fluid group I and II (refrigerants: toxic, non-toxic, flammable and non-flammable) and covered by Article 3, paragraph 3 in The Pressure Equipment Directive 97/23/EC, which means that:

- The products are designed in conformity with good technical practice in one of the member states.
- The products are not allowed to carry the CE mark referring to Directive 97/23/EC.
- An EC-Declaration of Conformity cannot be issued referring to Directive 97/23/EC.
- The products must not be used as safety equipment.

Date	Issued by	Date	Approved by
			
2005-07-08	Ole Lundby, Quality Assurance	2005-07-08	Gunnar Christensen, Product Manager