

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment:

Description of Vessel / Assembly: Ball, Globe & Check Valves

Models covered:

(Cat I) Ball Valves : 903511, 903613, 903617, 900511, 900613, 900617.

Globe Valves : RLV22, RLV22E, RLV26, RLV26E

Check Valves : NRV22, NRV22E, NRV26, NRV26E

Conformity and Assessment Procedure Followed

Category	I
Module	A
Certificate	0041/D/1
DN.	32 - 54

Classified for	Group 2 Gases
Design pressure	34.5 bar
Maximum Op. Temp	+150° C
Minimum Op.Temp	- 40° C

The following transposed European standards and other technical specifications have been used:

UL 207

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:

Plant Safety Ltd.

Parklands

Wilmslow Road

Didsbury

Manchester M20 2RE

Notified Body identification No. **0041**

Signed James M. Carr Quality Assurance Manager Date: 25.5.02
 (Responsible Person - Name and actual Title)

