

ROBA METALS GENK  
SLINGERWEG 31  
3600 GENK

## INSPECTION CERTIFICATE

Type 3.1 acc. EN 10204

Certificate No : 1000526573

DATE: 19.07.2022

Delivery No : 0085258899

Customer	ROBA METALS B.V		
Cust's Ref No	PO-0039680-1	Cust's Part No	11102
Our Order No	1200131821 / 20	Quantity	13.650,00 MTR
		Inspection Lot	020000778577

Designation	CuT m 015,875x0,90x5000 JE HSM R		
according to	EN 12735-1 R250 PED 2014/68/EU & CUSTOMER REQUIREMENTS		
Material	Cu-DHP		
Chem. Anal.:	CU>99,90-P:0,015-0,040	OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODmin	mm	>=15,785	15,870 - 15,880	6
ODmax	mm	<=15,965	15,900 - 15,910	6
ODav	mm	15,835 - 15,915	15,890 - 15,895	6
Smin	mm	>=0,810	0,820 - 0,830	6
Smax	mm	<=0,990	0,850 - 0,860	6
Sav	mm	0,828 - 0,846	0,840	6
LENGTH	mm	5000 - 5008	5007	6
WGHT/m	kg/m	0,3474 - 0,3564	0,3530 - 0,3540	6
Rm	N/mm <sup>2</sup>	>=250,0	287,0 - 291,6	6
A50	%	>=30,0	40,0 - 42,5	6
EXPANSION	%	>=30,0	OK	6
C TOT. RES. IN.	mg/dm <sup>2</sup>	<=0,38	0,14 - 0,21	6
ECT EN 1971	%	100	OK	-

### DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

19.07.2022

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

FORM N3

ISSUE: C

REV: 2

DATE: DEC. 2017



HELLENIC COPPER AND ALUMINIUM INDUSTRY S.A.

### COPPER @ ALLOYS EXTRUSION DIVISION:

S.A. Register No: 2836/06/B/86/48 Ministry of Economy and Development  
General Commercial Registry No: 303401000  
VAT No: EL 094061318 Athens S.A. Companies Tax Office  
Registered Office: 2-4 Mesogeion Avenue, Athens Tower  
2nd Building, Athens GR 11527, Greece  
[www.elvalhalcor.com](http://www.elvalhalcor.com)

**Offices @ Copper Tubes Plant**  
(Mailing Address)  
62nd km Athens-Lamia National Road  
Oinofyta - Viotia, GR 32011, Greece  
Tel.: +30 22620 48111  
Fax: +30 22620 48910  
[www.halcor.com](http://www.halcor.com)

**Brass Rods @ Tubes Plant**  
(Mailing Address)  
59th km Athens-Lamia National Road  
Oinofyta - Viotia, GR 32011, Greece  
Tel.: +30 22620 53120

**Foundry**  
60th km Athens-Lamia National Road  
Oinofyta - Viotia, GR 32011, Greece  
Tel.: +30 22620 53011  
**Domestic Sales Dept**  
Peripheral Unit of West Attica  
Municipality of Aspropyrgos  
Prari position-Moustaki  
Industrial Park Area VIPA VIOPA EM